



***Suggested Specification For Johndec Autosash System**

Autosash System

Fume cupboard(s) shall be fitted with the Johndec Autosash System, operated via the fume cupboard control module, the control buttons are to include up, down and stop.

The fume cupboard Autosash system shall also include an attendance sensor; if the sash system is left open and unattended for a period of 2 minutes the attendance sensor will command the sash to close automatically.